

Report on the result of monitoring the
margin available for cross-zonal
electricity trade in the Baltic States in
2022

Public Utilities Commission of Latvia, Estonian
Competition Authority, National Energy
Regulatory Council of Lithuania

September 2023

Introduction

The Regulation (EU) 2019/943 of the European Parliament and of the Council on the internal market for electricity (hereinafter - Regulation 2019/943) imposes a set of obligations on European transmission system operators (hereinafter - TSOs) with the aim to increase the transmission capacities made available for cross-zonal exchanges. These increases in capacities were identified as an efficient means to facilitate cross-zonal trade and to further integrate the electricity markets into the European Internal Energy Market.

Article 16(8) of Regulation 2019/943 establishes the minimum values for the capacity of the interconnection to be made available by transmission system operators for cross-zonal trade:

“8. Transmission system operators shall not limit the volume of interconnection capacity to be made available to market participants as a means of solving congestion inside their own bidding zone or as a means of managing flows resulting from transactions internal to bidding zones. Without prejudice to the application of the derogations under paragraphs 3 and 9 of this Article and to the application of Article 15(2), this paragraph shall be considered to be complied with where the following minimum levels of available capacity for cross-zonal trade are reached:

- (a) for borders using a coordinated net transmission capacity approach, the minimum capacity shall be 70 % of the transmission capacity respecting operational security limits after deduction of contingencies, as determined in accordance with the capacity allocation and congestion management guideline adopted on the basis of Article 18(5) of Regulation (EC) No 714/2009;
- (b) for borders using a flow-based approach, the minimum capacity shall be a margin set in the capacity calculation process as available for flows induced by cross-zonal exchange. The margin shall be 70 % of the capacity respecting operational security limits of internal and cross-zonal critical network elements, taking into account contingencies, as determined in accordance with the capacity allocation and congestion management guideline adopted on the basis of Article 18(5) of Regulation (EC) No 714/2009.

The total amount of 30 % can be used for the reliability margins, loop flows and internal flows on each critical network element.”

Article 59(1)(h) of Directive (EU) 2019/944 of the European Parliament and of the Council of 5 June 2019 on common rules for the internal market in electricity provides that the regulatory authority of each Member State is responsible for “Ensuring that transmission system operators make available interconnector capacities to the utmost extent pursuant to Article 16 of Regulation (EU) 2019/943”.

Baltic national regulatory authorities (hereinafter – NRAs) - Public Utilities Commission of Latvia (PUC), Estonian Competition Authority (ECA), National Energy Regulatory Council of Lithuania (NERC) prepared the report based on the data

presented by the Baltic TSOs – AS Augstsprieguma tīkls (AST) on June 19, 2023, AS Elering and AB Litgrid on June 26, 2023 on margin available for cross-zonal electricity trade (hereinafter – *MACZT*) between the Baltic States electricity systems for the day-ahead market on Alternative current (hereinafter – AC) lines, and give the evaluation on the extent to which *MACZT* has been complied with the provisions of Article 16(8) of the Regulation 2019/943 - if the 70% *MACZT* target have been reached.

Method used for monitoring cross-border *MACZT*

Baltic capacity calculation region (hereinafter – Baltic CCR) TSOs, according to Article 20(2) of Regulation 2015/1222 of 24 July 2015 establishing a guideline on capacity allocation and congestion management (hereafter – Regulation 2015/1222), have developed and Baltic CCR NRAs have approved Capacity calculation methodology (hereafter – CCM) within the Baltic Capacity Calculation Region in 2018¹. Additionally, 2018 CCM that is confirmed with Baltic CCR NRAs decisions is still waiting to be implemented and therefore is not applied yet, however the principles on calculation of capacities are the same as in 2015² CCM.

Cross-zonal capacities calculated for Baltic CCR borders are not affected by capacities calculated for trading with 3rd countries and therefore capacities provided to Baltic CCR borders shall be evaluated independently from capacities provided to 3rd countries.

According to Article 23 of Regulation 2015/1222, during capacity calculation each TSO shall respect the operational security limits and contingencies used in operational security analysis. In CCM Baltic CCR TSOs referred to Article 25, 32 and 38 of Regulation 2017/1485 of 2 August 2017 establishing a guideline on electricity transmission system operation, as well as Methodical guidelines for stable operation in BRELL Loop (synchronous operation area consisting of power systems of Belarus, Russia, Estonia, Latvia and Lithuania), in order to define operational security limits. These limits are voltage limits, short-circuit current limits, current limits in terms of thermal rating, stability limits, emergency reserves availability. Thermal limits of critical network elements are only one of several operational security limits, while other limits (e.g., voltage and stability limits) are not applicable/transformable to individual critical network elements, but to whole power system and therefore are applied to the cross-border interconnection – in such way representing allocation constraints of the respective border.

Article 16(8) of Regulation 2019/943 prescribes that for cross-zonal capacity determination using a coordinated net transmission capacity approach, applicable in Baltic CCR, the minimum capacity shall be 70 % of the transmission capacity, respecting operational security limits after deduction of contingencies, as determined in accordance with the Regulation 2015/1222.

¹ https://ast.lv/sites/default/files/editor/metodikas/Capacity_calculation_methodology_within_the_Baltic_Capacity_Calculation_Region21112018.pdf

² <https://elering.ee/node/262>

According to both - 2015 and 2018 CCM - Baltic CCR TSOs calculate maximum possible cross-zonal capacity for each alternating current (hereinafter - AC) interconnections (cross-borders) by taking into account all operational security limits, but not only thermal limits. Maximum possible cross-zonal capacity for each AC interconnections (cross- borders) is called Total Transfer Capacity (hereinafter – *TTC*). *TTC* of the designated Cross-Border Interconnection is the maximum transmission of active power, which is permitted in transmission Cross-Border Interconnection compatible with Operational Security standards and is calculated using common power system's grid model of Baltic TSOs, as well as Russia and Belarus power systems, with application of various contingencies from Baltic, Russian and Belarus power systems. Coordinated *TTC* value is used by power system dispatchers to control physical flows on the border. On the other hand, Baltic CCR TSOs allocate to electricity market coordinated Net Transfer Capacity (hereinafter – *NTC*) values which are calculated according to CCM reducing coordinated *TTC* value by Transmission Reliability Margin (hereinafter – *TRM*) value. Coordinated *TTC* value represents the maximum power exchange which is possible between two power systems through respective cross-border interconnection.

Baltic TSOs operate in synchronous area together with Russian and Belarus power systems, and, in real time operation, part of power goes not directly through cross-border between bidding zones, but around – also through Russian and Belarus networks. At the same time exchanges between Russian and Belarus power systems, resulting from 3rd countries power market operation, similarly like energy of European Union (hereinafter – EU) power market, partly transits also through power systems of Baltic states. In such situation limitation of power exchange between bidding zones on the market to the respective maximum transmission of active power of specific cross-border interconnection (and not considering possible capacity increase due to loop flows through neighbouring power systems) allows to keep status quo of transmission infrastructure usage and not to exploit infrastructure by one of power markets at the expense of other power market. Should be mentioned that there are no more market operations with Belarus, and market operations with Russia have been stopped.

Agency for the Cooperation of Energy Regulators (hereinafter – ACER) Recommendation No 01/2019 of 08 August 2019 on the implementation of the *MACZT* pursuant to Article 16(8) of CEP Regulation (hereafter – ACER Recommendation) provides approach for calculation and monitoring the *MACZT*.

From the ACER Recommendation follows that the maximum flow on critical network element (hereinafter – CNE), as referred to in Articles 23(3)(a) and 29(7)(a) of the Regulation 2015/1222 means the capacity respecting operational security limits taking into account (or after deduction of) contingencies of CNE as referred to in Article 16(8) of Regulation (EU) 2019/943 (hereinafter – F_{max}) is based on CNE thermal limits. Additionally, to that point 6.2 of ACER Recommendation stated that when constraints are needed to maintain the transmission system within operational security limits, and when such constraints cannot be transformed efficiently into F_{max} on CNEs, TSOs may introduce additional constraints ('allocation constraints') to be respected during

capacity allocation.

TSOs have obligation and practical need to use all operational security limits during capacity calculation, not only thermal limits of CNEs, as the result can be misleading showing not acceptable high theoretical cross-zonal capacities. To perform correct evaluation of compliance with 70% target threshold, all operational security limits are taken into account.

In Baltic CCR the coordinated *TTC* values for cross-border, which shall be calculated according to CCM and which takes into account all operational security limits, represent the maximum possible power flow on the cross-border (and at the same time is also maximum possible energy exchange between bidding zones), the correct and straightforward way of checking compliance with Regulation 2019/943 Article 16(8) for Baltic CCR AC borders is comparison of *NTCs* provided to the market with coordinated *TTC* value. Evaluation of compliance to 70% target shall be performed using the following formula:

$$MACZT(MTU) = NTC(MTU) \geq 70\% TTC (MTU), \quad (1)$$

where

MTU – Market Time Unit;

TTC – Total Transfer Capacity of the designated Cross-Border Interconnections is the maximum transmission of active power, which is permitted in transmission Cross-Border Interconnections compatible with Operational Security standards applicable for each TSO;

NTC – coordinated Net Transmission Capacity of the designated Cross-Border Interconnections is the maximum Trading Capacity, which is permitted in transmission Cross-Border Interconnections compatible with Operational Security standards and taking into account the technical uncertainties on planned network conditions for each TSO.

Baltic CCR CCM presents the following formulas of calculation of respective values.

NTC value for Estonia-Latvia Cross-Border Interconnection shall be calculated using following formula:

$$NTC = \min(((TTC_1 + \sum_{i=1}^n K_i P_i) - TRM); TTC_2 - TRM), \quad (2)$$

where

TTC_1 – Total Transfer Capacity after $N-1$ situation has occurred from actual power system network status according to Instruction for parallel operation in the Cross-Border Interconnection between Estonian, Russian and Latvian power systems. The "N" in "N-1" represents the total number of components or elements that need to be operational for the transmission system to function properly. The "-1" signifies that the system should still be able to operate safely and reliably even if one of those components fails. The value of TTC_1 is independent on influence of ambient temperatures – values at 0 (zero) temperature shall be used;

TTC_2 – Total Transfer Capacity value for actual power system network status, according to Instruction for parallel operation in the Cross-Border Interconnection between Estonian, Russian and Latvian power systems. The value of TTC_2 is dependent from the influence of ambient temperature of particular capacity calculation time period to transmission line conductors;

P_i – amount of assured emergency power reserves for respective power system i taking into account operational security of all Baltic CCR and interconnected AC power systems;

n – number of power systems;

K_i – reserve power distribution coefficients considering location of the assured emergency power reserve P_i ;

TRM – Transmission Reliability Margin value calculated according to the methodology described in Article 7 of this CCM.

TTC on Estonia-Latvia Border may be affected by amount of assured emergency power reserves and ambient temperature.

NTC values for Lithuania-Latvia Cross-Border Interconnection shall be calculated using following formula:

$$NTC = (TTC_1 + \sum_{i=1}^n K_i P_i) - TRM, \quad (3)$$

where

$$TTC_1 + \sum_{i=1}^n K_i P_i \leq TTC, \quad (4)$$

where

TTC_1 – Total Transfer Capacity after $N-1$ situation has occurred from actual power system network status according to Instruction for parallel operation in the Lithuania-Latvia Cross-Border Interconnection. The "N" in "N-1" represents the total number of components or elements that need to be operational for the transmission system to function properly. The "-1" signifies that the system should still be able to operate safely and reliably even if one of those components fails;

P_i – amount of assured emergency power reserves for respective power system i taking into account operational security of all Baltic CCR and interconnected AC power systems;

K_i – reserve power distribution coefficients considering location of the assured emergency power reserve P_i ;

n – number of power systems;

TTC – Total Transfer Capacity in actual power system network status according to Instruction for parallel operation in the Lithuania-Latvia Cross-Border Interconnection;
 TRM – Transmission Reliability Margin calculated according to the methodology described in Section 7 of CCM.

Analysis of $MACZT$

On 6 June 2023 Baltic NRAs requested Baltic TSOs the day-ahead Total Transfer Capacity (TTC) and Coordinated Net Transfer Capacity (NTC) data for evaluation in accordance with Article 16(8) of the Regulation 2019/943 and 70% target monitoring, and if in place the reasoning for limitations such as outage(s) causing the limitation, critical network element, outdoor temperature used for calculations, TTC and NTC coordination process.

The Baltic NRAs received from Baltic TSOs – AS Augstsprieguma tīkls (AST) on June 19, 2023, AS Elering and AB Litgrid on June 26, 2023, 2023 electrical letter with Annexes of each cross-border section between the Baltic States electrical systems:

- Annex 1 – 70% NTC target monitoring table EE-LV both directions 2022_Elering- AST data.
- Annex 2 – 70% NTC target monitoring table LV-LT both directions 2022_Litgrid- AST data.

1. Cross-border trade between Latvia (LV) and Estonia (EE).

Figure 1: Development of percentage of the $MACZT$ (NTC/TTC) for the day-ahead market direction LV-EE in a year 2022.





Figure 2: Percentage of the *MACZT* (as *NTC/TTC*) for the day-ahead market direction EE-LV in a year 2022



NTC on the cross-borders LV-EE was not lower than 84%.

NTC on the cross-borders EE-LV was not lower than 84%.

On the direction from EE to LV

The low level 84% of *MACZT* have been on 13.07.2022 for eight hours (08:00 - 16:00)³ and 89% for two hours (16:00 – 18:00) mentioned in UMM⁴. Maintenance on 330kV lines - Tartu-Balti EJ, Tartu-Valmiera (LV), Tsirguliina-Valmiera (LV).

On the direction from LV to EE

The low level 84% of *MACZT* have been on 28.06.2022 for nine hours (08:00 - 17:00) mentioned in UMM⁵. Maintenance on 330kV lines Tartu-Balti EJ, Tartu-Valmiera (LV).

The low level 84% of *MACZT* have been on 13.07.2022 for ten hours (08:00 - 18:00), 14.07.2022 for ten hours (07:00 – 17:00) and 15.07.2022 for nine hours (08:00 – 17:00) mentioned in UMM⁶. Maintenance on 330kV lines - Tartu-Balti EJ, Tartu-Valmiera (LV), Tsirguliina-Valmiera (LV).


³ Central European Time (CET) is used in the document including graphs,

⁴ <https://umm.nordpoolgroup.com/#/messages/dbc79559-a2ae-4300-a70c-453ac62cce91/10>

⁵ <https://umm.nordpoolgroup.com/#/messages/7e6d025c-48dd-4243-8d6e-d5faf491ba29/22>


⁶ <https://umm.nordpoolgroup.com/#/messages/dbc79559-a2ae-4300-a70c-453ac62cce91/10>

Figure 3. Percentage of the time for the available *MACZT* for the EE-LV cross-border in both directions (% of hours).



2. Cross-border trade between Latvia (LV) and Lithuania (LT).

Figure 4: Percentage of the *MACZT* (*NTC/TTC*) for the day-ahead market direction LV-LT in a year 2022




On the direction from LV to LT *MACZT* only eighteen hours on 30.05.2022 from 07.00 till 31.05.2022 01.00, have been lower than 100% (86%). The reason for that was in UMM⁷ maintenance of 330 kV OHLs Grobina-Klaipeda, Jurbarkas - Bitenai, Utena -

⁷ <https://umm.nordpoolgroup.com/#/messages/89da1a6b-6ab2-4674-96a5-6a8413a151ef/15>

Panevezys, Jelgava-Siauliai-Telsiai and 330 kV OHLs in Latvian grid. Other cases when the *MACZT* have been less than 100% (99%) was on 21.10.2022 from 22.00 till 01.11.2022 07.00 and from 02.11.2022 from 07.00 till 03.11.2022 06.00–. On 03.11.2022 from 10.00 till 09.11.2022. 00.00 (98% and 99%). The reason for that was in UMM - maintenance of 330 kV OHLs Grobina-Klaipeda, Jurbarkas - Bitenai, Jelgava-Siauliai-Telsiai, Klaipeda-Telsiai, Neris-Utena and 330 kV OHL in Latvian grid⁸ and maintenance of 330 kV OHLs Grobina-Klaipeda, Jurbarkas - Bitenai and Neris-Utena and 330kV OHL in Latvian grid⁹.

Figure 5: Percentage of the *MACZT* (*NTC/TTC*) for the day-ahead market direction LT-LV in a year 2022



On the direction from LT to LV

Twenty-two hours on 20.10.2022 from 22.00 till 21.10.2022. 22.00 was lower than 70% – 68%. The reason for that was in UMM, maintenance of 330 kV OHLs Grobina-Klaipeda, Jurbarkas - Bitenai, Neris-Utena and 330 kV OHL in Latvian grid¹⁰.

Other cases when the *MACZT* have been less than 100% (99%) was on 03.01.2022 from 08.00 till 04.01.2022 01.00 – for seventeen hours, maintenance of 330 kV OHL in Latvian grid¹¹.

NTCs on the cross-borders LV-LT were higher than 86%.

Figure 6. Percentage of the time for the available *MACZT* for the LV-LT cross-border


⁸ <https://umm.nordpoolgroup.com/#/messages/9384ac9a-a9bd-46ef-894c-4bdaac9e2bab/9>

⁹ <https://umm.nordpoolgroup.com/#/messages/6949e443-30e0-4c8b-8f74-11634b55361c/4>

¹⁰ <https://umm.nordpoolgroup.com/#/messages/8c6439d1-c6cd-46c4-8579-33b612057846/6>

¹¹ <https://umm.nordpoolgroup.com/#/messages/94677efe-5fd3-4bef-a787-dc8620357317/5>

in both directions (% of hours).



Conclusions and general remarks

- The report presents the Baltic NRAs monitoring of *MACZT* using the specific approach as described before, explaining the method of calculation of *MACZT*, taking into regard the specifics of Baltic States power systems operating within the BRELL.
- *MACZT* for the interconnections between the Baltic States electricity systems is in line with Regulation 2019/943. For cross-border Latvia – Estonia 100% of *MACZT* is available 67% of hours direction EE-LV and 73% of hours direction LV-EE. For Latvia – Lithuania cross-border in direction LT-LV *MACZT* for most of time (~ 99,5%) *MACZT* was 100%. The minimum value of *MACZT* 68% was twenty-two hours of the year 2022.
- Baltic CCM does not foresee common power transfer distribution factor (hereinafter – PTDF) calculation and CNECs identification process for each MTU. PTDF calculation, regarding to information provision to ENTSO-E and ACER pursuant to Article 82 of Regulation 2015/1222, is not required for *NTC* approach. Moreover, PTDF calculation and CNECs' identification and monitoring for Baltic CCR cross-borders is not available till the synchronization of Baltic States power systems with Continental Europe power systems. Baltic CCR TSOs informed that they are not capable to provide any historical information on CNECs F_{max} as well as scheduled commercial cross-border flows with third countries.
- Baltic TSOs reporting quality regarding the transparency is sufficient, TSOs have included the reasons of unavailable capacity in most cases, as well as the outdoor temperature in case of border between Lithuania and Latvia.
- All the necessary data in accordance with ACER recommendation on all the CNEs associated with a contingency used in capacity calculation will be available only after Baltic States electricity systems synchronization with Continental Europe in a year 2025. Common grid models would also not be available before the desynchronisation from BRELL.
- Baltic TSOs will accelerate the development of new CCM after 2025, the use of common grid models, and the identification of the CNEs associated with a contingency used in capacity calculation.